



City of Biggs

Agenda Item Staff Report City Council Meeting: February 9, 2016

TO: Honorable Mayor and Members of the City Council
FROM: City Administrator
Subject: Replace section of sewer line serving Biggs Community Hall

Council is asked to review the attached proposals to replace a section of sewer line serving Biggs Community Hall (BCH) and authorize the City Administrator to purchase professional services for the replacement of a section of the sewer line.

Background:

The sewer line serving BCH is in two primary sections. 1) from the building to a clean-out near the road; 2) An approximately 575' section from the clean out to a sewer main near the corner of B and 1st Streets.

Camera inspection verifies issues in each section, however clogging issues have only been experienced in the section of line from the BCH building to the clean-out.

The attached 2 estimates relate to the following:

- 1) \$4,500 to replace the section from the BCH building to the clean-out.
- 2) \$4,900 to replace an approx. 100' deteriorated section of the 575' section.
- 3) \$78,770.50 to replace the entire 575' section.

Staff recommends option #1, only replacing the repeatedly problem section from the BCH building to the cleanout.

Recommendation:

Authorize the City Administrator to purchase professional services to replace the section of sewer line from the BCH building to the clean-out, not to exceed \$5000.



Section of damaged pipe

Building Cleanout



© 2015 Google

Imagery Date: 4/14/2015 39°24'54.91" N 121°43'

1998